

# Emission Test Certificate

Tuesday October 2<sup>nd</sup>, 2007

Supplier: The Laminex Group

21 Trewin St

Wendouree Victoria 3355

Sample Description: Decorated Particleboard (Laminex Vertiboard)

Date Tested: September 2007

Test Method: ASTM D5116-97 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

## Decorated Particleboard

Total Volatile Organic Compound Emission Rate: 0.15 mg/m<sup>2</sup>/hr (7 days)

When this product is used in the typical manner in an office building the resulting airborne total volatile organic compound concentration can be expected to be less than 0.5 mg/m<sup>3</sup> as specified by Green Building Council of Australia Green Star Office Interiors IEQ-11.



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

**Project CV070820**